

ADDENDUM 2

New Pre K thru 5 Elementary School

180 Mungertown Road

Madison CT 06443

State Project No. 076-0067N

Tecton Project No. MAD02AR

Page 1

TO: Plan Holders

Project: **New Pre K thru 5 Elementary School**

Project #: **MAD02AR**

Owner: **Madison Public Schools**

Notice is hereby given that this Addendum forms a part of the Contract Documents and modifies the original Contract Documents as noted below.

A. SPECIFICATIONS

1. Section 00 01 10 Table of Contents, **REVISED** to include new spec sections added and sections deleted under Addendum #2
2. **ADDED** Section 00 31 19 Existing Conditions Information.
3. **ADDED** Section 00 31 19.01 Soils Investigation Report.
4. Section 00 30 00 Cast-in-place Concrete, **REVISED** Paragraph 3.10D.2b.
5. Section 06 40 23 Interior Architectural Woodwork, **DELETE** subparagraphs 1.05 B.4, 1.06 F, 2.01 C, **REVISED** sub-paragraphs 2.01 D & 2.01 E.
6. Section 06 41 13 Wood Veneer Faced Architectural Cabinets, **DELETE** Subparagraphs 1.05 B.4, 1.07 F & 2.03 C.
7. Section 07 41 13.16 Standing Seam Metal Roof Panels, **DELETE** Subparagraph 2.02 B.1a, **ADD** Subparagraphs 2.02 B.1b & 2.02B.1c.
8. **DELETE** Section 10 12 00 Display Cases.

B. DRAWINGS

1. Sheet L1.0, **ADDED** callout for Enlarged plan B12/L2.0
2. Sheet L2.0, **ADDED** Enlarged plan B12, Louver Style Fence Enlargement.
3. Sheet S1.00A:
 - **REVISED** footing elevations for underground pipes and depressed slab extent along grid line 7.
 - **REVISED** floor depression revised to match depression denoted on architectural drawings.

New Pre K thru 5 Elementary School**180 Mungertown Road****Madison CT 06443**

State Project No. 076-0067N

Tecton Project No. MAD02AR

4. Sheet S1.01B, **ADDED** steel frames at mechanical floor openings along grid line 13 & **REVISED** structural steel beam size along grid line 9 between H.8 and K.
5. Sheet A1.0A, **ADDED** fire extinguisher cabinets.
6. Sheet A1.10B, **ADDED** fire extinguisher cabinets.
7. Sheet A1.20B, **ADDED** fire extinguisher cabinets.
8. Sheet A1.30B, **ADDED** floor openings in slab on deck for duct penetrations.
9. Sheet A5.12, **REVISED** wall section H3.
10. Sheet A8.10, **REVISED** doors M44A, M44B, M79A & M79B, changed door panels to type N with type GL-2 fire rated glass lite.
11. Sheet I0.12, **REVISED** Tile Pattern elevation G5.
12. Sheet I2.10A, **REVISED** finished in Toilet M13.2.
13. Sheet M1.01B:
 - **REVISED** Ductwork within L03 due to beam conflict.
 - **REVISED** Duct riser location/dimensions in PE Office L11 due to beam conflict.
 - **ADDED** Fire Dampers in Electrical & Life Safety rooms per Code plan requirements.
 - **REVISED** 2" GS/R in Corridor L47 and routed to floor above.
14. Sheet M1.02B:
 - **REVISED** Pipe Size & Duct riser dimensions in M40 Custodial.
 - **ADDED** piping from floor below in M84 Instrumental Storage.
15. Sheet M3.00, **REVISED** GS/R pipe size within MER.
16. Sheet M3.01, **REVISED** GS/R pipe size within MER.
17. Sheet E0.10, **ADDED** power to geothermal vault septic pump and receptacle.
18. Sheet E5.02, **REVISED** panelboard SRPM-LL schedule.

New Pre K thru 5 Elementary School

180 Mungertown Road

Madison CT 06443

State Project No. 076-0067N

Tecton Project No. MAD02AR

C. CLARIFICATIONS

1. N/A.

Attachments:

- *Specification Sections 00 10 10, 00 31 19, 00 31 19.01, 03 30 00, 06 40 23, 06 41 13 & 07 41 13.16.*
- *Sheets L1.0 & L2.0*
- *Sheets SA.00A & S1.01B*
- *Sheets A1.10A, A1.10B, A1.20B, A1.30B, A5.12, A8.10, I0.12 & I2.10A*
- *Sheets M1.01B, M1.02B, M3.00, M3.01, E0.10 & E5.02*

END OF ADDENDUM 2