



- LIGHTING DRAWING NOTES:**
- ① PROVIDE POWER FOR PRE-WIRED BOOTHS. COORDINATE EXACT LOCATION WITH MANUFACTURER.
 - ② PROVIDE POWER FOR UNDER CABINET LIGHTING FROM LOCAL 120V RECEPTACLE.
 - ③ PROVIDE POWER FROM LOCAL LIGHTING CIRCUIT WITHIN ERU ON STANDBY POWER. COORDINATE EXACT MOUNTING LOCATION WITH ERU MANUFACTURER PRIOR TO INSTALLATION.

- LIGHTING CONTROL DRAWING NOTES:**
- ◊ REFER TO TYPICAL LIGHTING CONTROL 'MEPT SPACE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'STAIRWELL' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'RESTROOM' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'EXTERIOR' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'STORAGE/SUPPORT SPACE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'OFFICE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'OPEN OFFICE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CONFERENCE/LOUNGE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CORRIDOR' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CLASSROOM' DETAIL.

drawing title TERRACE LEVEL ELECTRICAL LIGHTING PLAN		STATE OF CONNECTICUT DEPARTMENT OF ADMINISTRATIVE SERVICES	
professional seal	REVISIONS	drawing prepared by BVH INTEGRATED SERVICES 206 WEST NEWBERRY ROAD BLOOMFIELD, CT. 06002	date 08/16/2019 scale 1/8" = 1'-0"
	mark date description	project SCSU NEW HHS BUILDING 501 CRESCENT STREET NEW HAVEN, CT 06505	drawn by MOS approved by AV
	1 08/16/19 ADDENDUM #2	project no. BI-RS-329	drawing no. EL.100