



- LIGHTING DRAWING NOTES:**
- ① PROVIDE POWER FOR PRE-WIRED BOOTHS. COORDINATE EXACT LOCATION WITH MANUFACTURER.
 - ② PROVIDE POWER FOR UNDER CABINET LIGHTING FROM LOCAL 120V RECEPTACLE.
 - ③ PROVIDE POWER FROM LOCAL LIGHTING CIRCUIT WITH ERU ON STANDBY POWER. COORDINATE EXACT MOUNTING LOCATION WITH ERU MANUFACTURER PRIOR TO INSTALLATION.

- LIGHTING CONTROL DRAWING NOTES:**
- ◊ REFER TO TYPICAL LIGHTING CONTROL 'MEPT SPACE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'STAIRWELL' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'RESTROOM' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'EXTERIOR' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'STORAGE/SUPPORT SPACE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'OFFICE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'OPEN OFFICE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CONFERENCE/LOUNGE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CORRIDOR' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CLASSROOM' DETAIL.

drawing title LEVEL 1 ELECTRICAL LIGHTING PLAN		STATE OF CONNECTICUT DEPARTMENT OF ADMINISTRATIVE SERVICES	
professional seal	REVISIONS	drawing prepared by BVH INTEGRATED SERVICES 206 WEST NEWBERRY ROAD BLOOMFIELD, CT. 06002	date 08/16/2019 scale 1/8" = 1'-0"
	mark date description	project SCSU NEW HHS BUILDING 501 CRESCENT STREET NEW HAVEN, CT 06505	drawn by MOS approved by AV
	1 08/16/19 ADDENDUM R2	project no. 501 CRESCENT STREET NEW HAVEN, CT 06505	drawing no. EL.1.01
		CAO no. BI-RS-329	