



- LIGHTING DRAWING NOTES:**
- ① PROVIDE POWER FOR PRE-WIRED BOOTHS. COORDINATE EXACT LOCATION WITH MANUFACTURER.
 - ② PROVIDE POWER FOR UNDER CABINET LIGHTING FROM LOCAL 120V RECEPTACLE.
 - ③ PROVIDE POWER FROM LOCAL LIGHTING CIRCUIT WITHIN ERU ON STANDBY POWER. COORDINATE EXACT MOUNTING LOCATION WITH ERU MANUFACTURER PRIOR TO INSTALLATION.
- LIGHTING CONTROL DRAWING NOTES:**
- ◊ REFER TO TYPICAL LIGHTING CONTROL 'MEPT SPACE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'STAIRWELL' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'RESTROOM' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'EXTERIOR' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'STORAGE/SUPPORT SPACE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'OFFICE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'OPEN OFFICE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CONFERENCE/LOUNGE' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CORRIDOR' DETAIL.
 - ◊ REFER TO TYPICAL LIGHTING CONTROL 'CLASSROOM' DETAIL.

drawing title			STATE OF CONNECTICUT	
ROOF ELECTRICAL LIGHTING PLAN			DEPARTMENT OF ADMINISTRATIVE SERVICES	
professional seal	REVISIONS		drawing prepared by	date
	mark	date description	BVH INTEGRATED SERVICES	08/16/2019
	1	09/18/19 ADDENDUM R2	206 WEST NEWBERRY ROAD	scale
			BLOOMFIELD, CT. 06002	1/8" = 1'-0"
			project	drawn by
			SCSU NEW HHS BUILDING	MOS
			501 CRESCENT STREET	approved by
			NEW HAVEN, CT 06505	AV
			drawing no.	EL1.05
			project no.	
			BI-RS-329	